

# 73A-100 Series



Carbon Steel Ball Valve

Threaded, 1/4" to 1" 2000 psig WOG, 1-1/4" to 2" 1500 psig WOG Cold Non-Shock. 150 psig Saturated Steam. (See referenced P/T chart)

Vacuum Service to 29 inches Hg.

Federal Specification: WW-V-35C, Type: II, Composition: CS, Style: 3.

MSS SP-110; Ball Valves Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.

## **FEATURES**

- RPTFE seats & packing
- Forged construction
- Raised handle stops

- Blow-out-proof stem design
- Adjustable packing gland
- Zinc phosphate corrosion protection
- (-24) Fire safe to API 607 4th ed. class 600 burn


with vinyl

## STANDARD MATERIAL LIST

6. Ball 1. Lever nut Steel, zinc plated A108-CS chrome plated 2. Gland nut 7. Seat (2) A108-CS RPTFE 8. Body A105 3. Stem packing **MPTFE** A216-WCB 9. Stem bearing **RPTFE** 4. Retainer RPTFE (1/2" to 2") A108-CS 5. Body seal 10. Stem 11. Lever/grip Steel, zinc plated,


VARIATIONS AVAILABLE: 73A-140- Series (316 SS Ball & Stem NACE compliant)

## **OPTIONS AVAILABLE:**



### CARBON STEEL BALL VALVE

NUMBER	SIZE	A	В	С	D	Е
73A-101-01A	1/4"	.37	1.02	2.30	1.72	3.85
73A-102-01A	3/8"	.37	1.08	2.37	1.72	3.85
73A-103-01A	1/2"	.50	1.18	2.31	1.78	3.85
73A-104-01A	3/4"	.68	1.57	3.07	2.07	4.75
73A-105-01A	1"	.87	1.73	3.40	2.18	4.75
73A-106-01	1-1/4"	1.00	1.98	3.97	2.72	5.50
73A-107-01	1-1/2"	1.25	2.14	4.32	3.12	7.75
73A-108-01	2"	1.50	2.73	5.44	3.27	7.75



AAR Approval No. E999032 (when -52 is specified)

For Pressure/Temperature Ratings, Refer to Page M-12, Graph No. 13 (1/4" to 1") Refer to Page M-11, Graph No. 11 (1-1/4" to 2")

# FLOW DATA

## For Apollo® Ball Valves

The listed Cv "factors" are derived from actual flow testing, in the Apollo® Ball Valve Division, Conbraco Industries, Inc., Pageland, South Carolina. These tests were completed using standard "off the shelf" valves with no special preparation and utilizing standard schedule 40 pipe. It should be understood that these factors are for the valve only and also include the connection configuration. The flow testing is done utilizing water as a fluid media and is a direct statement of the gallons of water flowed per minute with a 1 psig pressure differential across the valve/connection unit. Line pressure is not a factor. Because the Cv is a factor, the formula can be used to estimate flow of most media for valve sizing.

## Flow of Liquid

$$Q = Cv \sqrt{\frac{\Delta P}{SpGr}}$$

or 
$$\Delta P = (Q)^2 (SpGr)^2$$

Where:

Q = flow in US gpm  $\Delta P = pressure drop (psig)$  SpGr = specific gravity atflowing temperature

Cv = valve constant

#### Flow of Gas

$$Q = 1360 \text{ CV} \sqrt{\frac{(\Delta P) (P_1)}{(SpGr) (T_1)}}$$

or 
$$\Delta P = 5.4 \times 10^{-7} (SpGr) (T)$$
  
(Q)<sup>2</sup> (Cv)<sup>2</sup> (P<sub>2</sub>)

Where:

Q = flow in SCFH

 $\Delta P = \text{pressure drop (psig)}$ 

SpGr =specific gravity

(based on air = 1.0) P<sub>1</sub> = outlet pressure-psia

(psig + 14.7)

T = (temp. °F + 460)

Cv = valve constant

### Cv FACTORS SERIES:

70-100, 71-100, 71AR, 73A-100, 74-100, 76-100, 76AR, 80-100 81-100, 89-100

SIZE	1/4"	3/8"	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"
<b>OPEN</b>   90°	8.4	7.2	15	30	43	48	84	108	503	370	670

#### Cv FACTORS 76F, 77, 77AR, 77C, 77D SERIES

SIZE		1/4"	3/8"	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"
OPEN	90°	8.1	15	15	51	68	125	177	389	503

#### Cv FACTORS


#### 82-100/200, 83R-100/200/700,85R-100/200,86R-100/200/700,83-500/600,86-500/600/900 SERIES

SIZE		1/4"	3/8"	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"
OPEN	<b>9</b> 0°	8.1	14	26	51	68	120	170	376	510	996	1893


#### Cv FACTORS 83A/83B, 86A/86B, 86C SERIES

SIZE	1/4"	3/8"	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"
OPEN   9	0° 8.1	14	26	51	68	120	170	376


# 2000# CS P-T Rating (Graph 13)



# 2000# SS P-T Rating (Graph 14)



# 1500# CS P-T Rating (Graph 11)



# 1500# SS P-T Rating (Graph 12)

